



Bid Questions and Answers Report

Date & Time: 1/25/2017 3:05:01 PM

District Address: District 1 Construction Office, located at 801 N Broadway, Bartow, FL 33830

District Phone: (863) 519-2222

Proposal: T1666

Project: 432897-1-52-01

Letting Date: 1/25/2017

Location: CENTRAL OFFICE

Description: AVE J, AVE K AND SR 25 (US 27)

Question:	16979: The Widening and Shoulder Pavement Detail on plans for Project No. 434963-1-52-01, sheet No. 6 shows Optional Base Group 01 for Shoulder Pavement Widening. However, no pay item is given for this base group. On the contrary, a pay item for Optional Base Group 09 is provided, but not shown in the plans. Could you please clarify this discrepancy?	Posted:	1/11/2017 2:42:10 PM
Answer:	For clarification, the intent is to use Base Group No. # 09 for the shoulder pavement widening. The Base Group # 09 quantity that is shown on the Summary of Quantities Sheet SQ-10 should be used for bidding purposes.	Status:	ANSWER PUBLISHED
		Posted:	1/12/2017 1:54:07 PM
Question:	17076: The "Optional Materials Tabulation" for Drainage Pipe does not include Polypropylene Pipe as an acceptable material. We are asking for Polypropylene Pipe to be allowed/included as an optional pipe material (as long as min/max cover requirements are met).	Posted:	1/17/2017 11:56:36 AM
Answer:	Yes, Polypropylene Pipe will be allowed as an acceptable material given that the min/max cover requirements are met. It should be noted that it cannot be used for the elliptical pipes from S-1 to S-2.	Status:	ANSWER PUBLISHED
		Posted:	1/18/2017 1:16:04 PM